

SPD1804

Separation plates for MCS and MCD enclosures



H	1800
D	400
Item no.	SPD1804

Description: Separates two bayed MCS/MCD enclosures.

Material: 1.5 mm zinc plated steel.

Mounting requirements: IP 43 | TYPE 1 sealing can be obtained by using SPDG gasket. CCJ brackets are required to mount the SPD into the enclosures. To bay enclosures together, use CCM and CCI brackets. For EMI shielding the SPDEG gasket must be used.

Pack quantity: 1 piece.

This steel separation plate separates bayed enclosures while maintaining the IP rating, creating individual spaces for components to be mounted.