

CERTIFICATE

Issued to:
Applicant:
Eldon Group
Paseo de la Finca
28223 Madrid, Spain

Manufacturer/Licensee:
Eldon Group
Paseo de la Finca
28223 Madrid, Spain

Products : Terminal boxes
Trade name : ELDON
Types/models : STB...
SSTB...

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 62208:2011; IEC 62208:2011;
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 929318

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.


This certificate is issued on: 5 December 2014 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2171237.03

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



F.S. Strikwerda
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

| | | |
|---|---|---|
| Product | : | Terminal boxes |
| Trade name | : | ELDON |
| Types | : | STB... SSTB... |
| Type of material | : | STB: Powder painted steel SSTB: Stainless steel |
| Method of fixing | : | Wall mounting |
| Location | : | Powder painted steel: indoor Stainless steel: outdoor |
| Dimensions | : | Height: 150-400 mm Width: 150-800 mm Depth: 80-120 mm |
| Degree of protection | : | IP66 |
| Degree of protection against mechanical impacts | : | IK08 |
| Permissible load | : | Max 5 kg on door Max 10 to 40 kg on mounting plate |

Additional information

Type designation:
Example: SSTB203012

SSTB : basic type enclosure
SSTB = terminal box stainless steel
203012 = Dimensions, height x width x depth = 200 x 300 x 120 mm

TESTS**Test requirements**


EN 62208:2011
IEC 62208:2011

Test result

The test results are laid down in DEKRA test file 2171237.03.

Conclusion

The examination proved that all test requirements were met.

Tested by : C.C. Burger 

Checked by : H.L. Schendstok 

Factory locations

SC ELDON Romania SRL
Calle Bruxelles no. 4, 507165, Prejmer Brasov
Romania

Eldon Electric Ltd
Rother Way, S66 8QN, Rotherham South Yorkshire
Great Britain

M/S Eldon CS Enclosures Pvt. Ltd.
A1/285/1, GIDC, 396 171, Umbergaon
India