

## **Declaration of Compliance**

We: ELDON Group

Pº de la Finca 1, Ed 3

Madrid 28223

declare under our sole responsibility that the product ranges

MPC, MPCS, MPG, MPGS, Consoles

to which this declaration relates, comply with the relevant requirements stated in the standard IEC 61439-1&2:2011 (Low-voltage switchgear and controlgear assemblies – Part 1: General rules) for empty enclosures:

Section 8.1 Strength of material and parts

Section 8.2 Degree of protection

The compliance has been verified through the empty enclosures certification following the standard IEC 62208:2011 (Empty enclosures for low-voltage switchgear and controlgear assemblies – General requirements), which has been issued by DEKRA in the following certificates:

KEMA Certificate 95.4086.03

MPC, MPCS, MPG, MPGS

In addition, ELDON also declares that an enclosures assembly, built using ELDON enclosures and accessories, and following the mounting instructions available on Eldon's website, complies with IEC 61439-1&2:2011 (Low-voltage switchgear and controlgear assemblies).

Madrid, 3rd May 2017

Nicolás Mediavilla Abellán,

**Product Manager**