



Lloyd's
Register

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

This certificate is issued to:

PRODUCER

ELDON Group
Paseo de la Finca 1, Edificio 3
Pozuelo de Alarcón, 28223 Madrid
Spain

**PLACE OF
PRODUCTION**

SC ELDON Romania SRL
Street Bruxelles No. 4
507165 Prejmer Brasov
ROMANIA

Certificate No. 05/30022 (E3)
Issue Date 28 March 2017
Expiry Date 31 March 2019
Sheet 1 of 2



**PRODUCT
DESCRIPTION**

Floor standing enclosures

TYPE

MKS (E) series, mild steel, single door
Degree of protection IP 66.

MKD (E) series, Mild steel, double doors
Degree of protection IP 55

MCS (E) series, mild steel, single door with side panels as accessory
Degree of protection IP 56 with front doors and side panels.

MCD (E) series, Mild steel , double doors, with side panels as accessory
Degree of protection IP 55 with front doors and side panels.

MCI series, Mild steel with door and side panels as accessory
Degree of protection IP 56 with door and side panels.

MCSS series, stainless steel with door and side panels as accessory

MCDS series, stainless steel with double door and side panels as
accessory

EKSS series, stainless steel with door and side panels as accessory

EKDS series, stainless steel with double door and side panels as
accessory

APPLICATION

marine use

"This Certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid certificate."

The attached Design Appraisal Document No. ROT.TA. BBO1602085 and its supplementary Type Approval Terms and Conditions form part of this Certificate.

Certificate No. 05/30022 (E3)

Issue Date 28 March 2017

Expiry Date 31 March 2019

Sheet 2 of 2

G.J.Vromans
Type Approval Department
Lloyd's Register EMEA/Rotterdam Office



All other details remain as the previous Certificate No. 05/30022 to which this extension should be attached.

Certificate No.	05/30022 (E3)
Issue Date	28 March 2017
Expiry Date	31 March 2019
Sheet	3 of 2

