ATTESTATION OF CONFORMITY

Issued to: ELDON Group

Paseo de la Finca 1 Edificio 3

Pozuelo de Alarcón 28223 Madrid

Spain

For the product: Enclosures

Trade name: Eldon

Type/Model: HDW Series

Ratings: IP66, IP69, IP69K

Manufactured by: ELDON SRL

Str. Bruxelles nr. 4 Parcul Industrial Graells & Llonch

507165 Preimer, Jud. Brasov

Romania

Subject: Degree of protection provided by enclosure

Requirements: IEC 60529:1989 + A1:1999 + A2:2013

EN 60529:1991 + A1:2000 + A2:2013

NEN-ISO 20653:2013

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in test report 2229019.01-INC issued on 6 December 2018.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 6 December 2018 Number: 2229019.01-AOC

DEKRA Certification B.V.

H.R.M. Barends Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands T +31 88 96 83000 F +31 88 96 83100 www.dekra-certification.com Company registration 09085396